


Installation Instructions

Project Planning and Preparation(s)

What you will need for parts and pieces...




Step One: Take a lineal measurement of the overall length of the portion of the building where you plan to instal the border tube(s).

Step Two: Divide the overall length by the best stock sized tube(s) to achieve the most esthetically appealing installation. For example if this building was 41' long the optimal sized tube would be ARBT-98-CW meaning that the tube is 98" long and Cool White in color. Based on that you would specify (5) of this unit P/N to complete the project with the least amount of seams.


Project Planning laying out the installation:

Where you will apply the border tubes and proven methods for layout.....




Step Three: using a Level or a Chalk line make a line across the entire length of the installation This will ensure that each tube applied will stay on the same level plane.

Step Four: after you have determined how may mounting clips you will need, install them spaced according to the length of the specified tube(s), spacing them + or - 24.5" on center. for pieces less than 26" long you will install the fixture using one spring clip on each end.



Project installation and wiring:

Note: all electrical connections must be completed by qualified person(s) and in accordance to local electrical codes.....



Step Five: Install the border tubes beginning at an end while making sure not to compress the soft end caps leaving a minimum of 1/4" between each fixture, thus allowing for normal expansion and contraction.

Step Six: Make all electrical connections based on the manufacturers' recommendations and test lighting. Finish all connections and apply primary power and verify all tubes are lighting.

Tools Needed and Caution for Installation



Level



Tape Measure



Chalk Line



Drill / Hammer Drill



Linemen's Plyers



Philips /Robertson Head Screw Driver



Do not cut this product without using the <u>Field Cut Kit</u> and without referencing the Field Cut Kit Instructions.







Handle with care,
Do Not Force, striking this product will Void Warranty


Installation and Mounting Hardware Spring Clip

Stainless Steel Snap Clip Based on the different installation conditions the fastener will be determined and provided by the installer. The stainless steel spring snap clip needs to be installed at each end of each border tube fixture. they **Stainless** Aluminum should be installed flush to the end of every fixture and be used to secure the fixture. SteelClip Slide Clip *Once the tubes are in place using your thumb and index finger pinch the stainless snap clip tabs together ensuring that they are tight and secure. In cases where you are mounting the tubes in a vertical position you will need to employ a retainer clip seen below. The Wire Retainer Clip has points that wrap around the end(s) of the tube holding it from sliding up or down. Wire Retainer Clip Incorrect Do not use pliers see note* 25" max 25" max -Mandatory: maintain straight plane

The position of the Stainless Steel Snap and Aluminum Slide clips are vital to a successful installation both from a mechanical and esthetic view. There should not be any section of the installation that measures longer than 25" without an Aluminum Slide clip in place as directed.

Correct

Installation and Mounting Hardware In-line Brackets





Note: as little as five degrees off will alter the tube enough to noticeably distort the overall line.

Mounting Hardware

PART#	Stainless Steel Snap	Aluminum Slide	Wire Retainer	
	Clip	Clip	Clip	
ARBT-04	2	0	1	
ARBT-07	2	0	1	
ARBT-09	2	0	1	
ARBT-11	2	0	1	
ARBT-14	2	0	1	
ARBT-16	2	0	1	
ARBT-19	2	0	1	
ARBT-21	2	0	1	
ARBT-23	2	1	1	
ARBT-26	2	1	1	
ARBT-28	2	1	1	
ARBT-31	2	1	1	
ARBT-33	2	1	1	
ARBT-35	2	1	1	
ARBT-38	2	1	1	
ARBT-40	2	1	1	
ARBT-43	2	1	1	
ARBT-45	2	1	1	
ARBT-47	2	1	1	
ARBT-50	2	1	1	
ARBT-52	2	1	1	
ARBT-55	2	2	1	
ARBT-57	2	2	1	
ARBT-59	2	2	1	
ARBT-62	2	2	1	
ARBT-64	2	2	1	
ARBT-67	2	2	1	
ARBT-69	2	2	1	
ARBT-71	2	2	1	
ARBT-74	2	2	1	
ARBT-76	2	2	1	
ARBT-79	2	3	1	
ARBT-81	2	3	1	
ARBT-83	2	3	1	
ARBT-86	2	3	1	
ARBT-88	2	3	1	
ARBT-91	2	3	1	
ARBT-93	2	3	1	
ARBT-95	2	3	1	
ARBT-98	2	3	1	

Installation and Secondary Fixture Wiring





Installation and service of these products should be done by qualified personnel.

Use only with Class 2 Power Supply.



CAUTION RISK OF ELECTRIC SHOCK



To reduce the risk of electric shock, disconnect all connections before servicing.

0321

